Networkable Fan Coil Controller
Specification and Installation Instructions

EFCB Series

EFCB10TU2 *(24Vac / 2 relays)*
EFCB10TU4 *(24Vac / 4 relays)*

EFCB11TU2 *(120Vac / 2 relays)*
EFCB11TU4 *(120Vac / 4 relays)*

EFCB12TU2 *(240Vac / 2 relays)*
EFCB12TU4 *(240Vac / 4 relays)*

TFL54 Series Digital Room Sensor

TFL54 *(With temperature sensor)*
TFLH54 *(With temperature and humidity sensor)*

TDF Series Digital Room Sensor

TDF00 *(Vertical Grey LCD, white enclosure)*
TDF30 *(Vertical Black LCD, black enclosure)*
TDF60 *(Vertical Black LCD, white enclosure)*

TDF10 *(Horizontal Grey LCD, white enclosure)*
TDF40 *(Horizontal Black LCD, black enclosure)*
TDF70 *(Horizontal Black LCD, white enclosure)*





EFCB Series



TFL54 or TFLH54



TDF00 / TDF30 / TDF60 Series



TDF10 / TDF40 / TDF70 Series


Description


The EFCB Series Networkable Fan Coil Controller and TFL54 and TDF Series Digital Room Sensors are designed for simple and accurate control of any fan coil application. The Networkable Fan Coil Controller is mounted inside the fan coil cabinet and incorporates a configurable fan coil algorithm, variable three speed fan control and either modulating or digital heating and cooling outputs. All inputs and high/low voltage outputs are centralized at the control module in the fan coil cabinet.

Applications

- Compatible with 2 or 4 pipe systems
- Fan coil unit (up to 3 speeds and/or analog 0-10 Vdc)
- Cooling signal (on/off, floating or modulating 0-10 Vdc)
- Heating signal (on/off, floating, pulse or modulating 0-10 Vdc)
- Cool, Heat, Reheat, Reheat with fan, Changeover, Fan, Humidify and Dehumidify by cooling.

Typical Application





Features

- Built-in configurable fan coil algorithms
- Up to 10 inputs and 15 outputs (configurable)
- Select direction on digital inputs and all outputs
- Selectable proportional control band and dead band
- Selectable fan speed contacts
- Independent cool/heat setpoint for NSB/OCC mode
- No occupancy and NSB override
- Selectable internal or external temperature sensor (10KΩ)
- Change over by contact or 10KΩ temperature sensor
- Internal and external temperature sensor calibration
- Freeze protection
- Multi level lockable access menu and setpoint
- Removable, raising clamp, non-strip terminals

Digital Room Sensors Features

- Backlit LCD with simple icon and text driven menus
- Select digital room sensor's default display
- BACnet service port via on-board mini USB connector
- Selectable Fahrenheit or Celsius scale
- 3-wire connection to controller and 4 push buttons

Network Communication

- BACnet® MS/TP or Modbus communication port
- Select MAC address via DIP switch or via network
- Automatic baud rate detection


BACnet MS/TP®

- Automatic device instance configuration
- Copy & broadcast configuration via digital room sensor menu or via BACnet to other controllers
- BACnet scheduler
- Firmware upgradeable via BACnet
- Support COV (change of value)


Modbus

- Modbus @ 9600, 19200, 38400 or 57600 bps
- RTU Slave, 8 bits (configurable parity and stop bits)
- Connects to any Modbus master

Controller Specifications

Description	EFCB10TU2 EFCB10TU4	EFCB11TU2 EFCB11TU4	EFCB12TU2 EFCB12TU4
Inputs	2 fixed analog inputs (external temp. and changeover sensors); 10KΩ or contact 4 analog inputs (0-10 Vdc or 10 KΩ via DIP switches) 3 configurable digital inputs 1 night setback or occupancy sensor input		
Outputs	4 analog, 0-10 Vdc configurable outputs (changeover/cooling/heating, fan, humidity) 4 configurable TRIAC outputs (changeover/cooling/heating) 3 speed fan (Motor and/or compressor inductive ratings: ¼ Hp/10 LRA/2.5 FLA 240 Vac Maximum Resistive ratings: 7 Amp/1680 W at 240 Vac Maximum); configurable up to 3 speeds 2 or 4 configurable digital outputs (changeover/cooling/heating, humidity, 3A dry contact)		
Power supply	24 Vac	120 Vac	240 Vac
Power consumption	8 VA max. 24 Vac thermal fused.		
BACnet	BACnet® MS/TP @ 9600, 19200, 38400 or 76800 bps (BAS-C)		
Modbus	Modbus RTU slave @ 9600, 19200, 38400 or 57600. Selectable parity and stop bit configuration: No parity, 2 stop bit Even parity, 1 stop bit Odd parity, 1 stop bit		
Communication Connections	24 AWG twisted-shield cable (Belden 9841 or equivalent)		
Electrical Connections	0.8 mm^2 [18 AWG] minimum		
Operating temperature	0ºC to 50ºC [32ºF to 122ºF]		
Storage temperature	-30ºC to 50ºC [-22ºF to 122ºF]		
Relative Humidity	5 to 95% non condensing		
Enclosure protection	IP 30 (EN 60529)		
Weight	635 g. [1.4 lb]		
Dimensions: A = 6.30" | 160mm B = 5.00" | 126mm C = 2.25" | 57mm			


Digital Room Sensor Specifications

Description	TFL24 and TDF Series
Temperature Sensor (TFL54 and TFLH54)	
Setpoint Range	10ºC to 40ºC [50ºF to 104ºF]
Control Accuracy	±0.5ºC [0.9ºF] @ 22ºC [71.6ºF] typical calibrated
Display Resolution	±0.1ºC [0.2ºF]
Humidity Sensor (TFLH54, and TDF models with Humidity Sensor)	
Setpoint Range	10 to 65%RH
Control Accuracy	±3.5% RH
Display Resolution	0.1%
CO_2 Sensor (TDF models with CO_2 Sensor)	
Operating Principle	Self-calibrating, Non-Dispersive Infrared (NDIR)
Sensor Range	400 to 2000 ppm
Accuracy	±30 ppm ±3% of reading (Accuracy is defined after minimum 3 weeks of continuous operation)
Response Time	2 minutes by 90%
PIR Motion Sensor (TDF00 / TDF30 / TDF60 models with PIR Sensor)	
Operating Principle	Passive Infrared (PIR)
Detection Angle	100°
Detection Distance	4m [13ft]
Detection Area	
VOC Sensor (TDF00 / TDF30 / TDF60 Series models with VOC Sensor)	
Operating Principle	Self-calibrating, Non-Dispersive Infrared (NDIR)
Sensor Range	0-1000 ppb isobutylene equivalent tVOCs
Response Time	<5 seconds for tVOC
Start up Time	15 mintues
Other	
Electrical connection	3 wires to EFCB controller and 2 wires (optional) to BACnet network service port 0.8 mm^2 [18 AWG] minimum
BACnet service port	Mini USB connector
Power supply	24Vac or 24Vdc
Power consumption	1VA
Operating temperature	0ºC to 50ºC [32ºF to 122ºF]
Storage temperature	-30ºC to 50ºC [-22ºF to 122ºF]
Relative humidity	5 to 95 % non condensing
Enclosure protection	IP 30 (EN 60529)
Weight	80 g. [0.18 lb]
Note: The TFL54/TDF digital room sensor functions only with the EFCB controller. All the inputs/outputs are located on the EFCB except for the temperature, humidity and CO_2 sensors built-in the TFL54/TDF and PIR and VOC sensors built in the TDF00 / TDF30 / TDF60 models.	

Dimensions


TFL54

A = 3.00 in (78mm)
B = 3.00 in (78mm)
C = 1.00 in (24mm)
D = 2.36 in (60mm)




TDF10 / TDF40 / TDF70 Series

A = 5.24” | 133mm
B = 2.87” | 73mm
C = 3.74” | 95mm
D = 1.22” | 31mm
E = 0.75” | 19mm
F = 2.00” | 51mm
G = 2.18” | 55mm



TDF00 / TDF30 / TDF60 Series

A = 4.88” | 124mm
B = 3.25” | 83mm
C = 1.75” | 44mm
D = 0.96” | 24mm
E = 2.07” | 53mm
F = 2.36” | 60mm
G = 3.28” | 83mm
H = 0.78” | 20mm *(without CO_2)*
0.95” | 24mm *(with CO_2)*



TDF Models

Horizontal Model #	Temp	RH	CO_2
TDF10-100 TDF40-100 TDF70-100	•		
TDF10-101 TDF40-101 TDF70-101	•	•	
TDF10-102 TDF40-102 TDF70-102	•	•	•
TDF10-103 TDF40-103 TDF70-103	•		•



TDF10 Series



TDF40 Series



TDF70 Series

Vertical Model #	Temp	RH	CO_2	PIR	VOC
TDF00-100 TDF30-100 TDF60-100	•				
TDF00-101 TDF30-101 TDF60-101	•	•			
TDF00-102 TDF30-102 TDF60-102	•	•	•		
TDF00-103 TDF30-103 TDF60-103	•		•		
TDF00-104 TDF30-104 TDF60-104	•			•	
TDF00-105 TDF30-105 TDF60-105	•	•		•	
TDF00-106 TDF30-106 TDF60-106	•	•	•		•
TDF00-107 TDF30-107 TDF60-107	•	•	•	•	•
TDF00-108 TDF30-108 TDF60-108	•	•	•	•	



TDF00 Series




TDF30 Series



TDF60 Series


Interface

TFL54




A	Cooling ON A: Automatic		Programming mode (Technician setting)		Alarm status
A	Heating ON A: Automatic		Menu set-up Lock		Energy saving mode
A	Fan ON 3rd speed activated A: Automatic	MIN MAX	Minimum/Maximum	°C or °F	°C: Celsius scale °F: Fahrenheit scale

TDF10 / TDF40 / TDF70 Series



	Network Communication		User Lock		Programming Mode (Technician Setting)
	Alarm Status		Energy Saving Mode (NSB/OCC)	1 2 3 4 5 6 7	Schedule
88:88 AM PM	Time	ppm	Parts Per Million	°C °F %RH	°C: Celsius Scale °F: Fahrenheit Scale %RH: Humidity
A	Automatic Mode		Cooling		Heating
	Fan		Humidify		De-humidify

TDF00 / TDF30 / TDF60 Series




	Network Communication		User Lock		Programming Mode (Technician Setting)
	Alarm Status		Energy Saving Mode (NSB/OCC)	AM PM	Time
°C °F %RH	°C: Celsius Scale °F: Fahrenheit Scale %RH: Humidity	A	Automatic Mode		Cooling
	Heating		Fan		Humidify/ De-humidify

Mounting Instructions

TFL54

CAUTION: Remove power to avoid a risk of malfunction.


A. Remove the captive screw that's holding the base and the front cover of the unit together.
B. Lift the front cover of the unit to separate it from the base.
C. Pull all wires through the holes in the base.
D. Secure the base to the wall using wall anchors and screws (supplied). Make the appropriate connections.
E. Mount the control module on the base and secure using the screw.



TDF10 / TDF40 / TDF70 Series

CAUTION: Remove power to avoid a risk of malfunction.


A. Remove the wall mounting plate (highlighted) from the back of the digital room sensor.
B. Install the mounting plate on the gang box.
C. Pull the wires through the base hole and make the appropriate connections.
D. Mount the digital room sensor onto the wall plate. To mount it correctly, place the top of the digital room sensor on the mounting plate first and push it into the grooves to snap it into place.
E. Secure the digital room sensor using the screw (supplied).



TDF00 / TDF30 / TDF60 Series

CAUTION: Remove power to avoid a risk of malfunction.

A. Remove the captive screw that's holding the base and the front cover of the unit together.
B. Lift the front cover of the unit to separate it from the base.
C. Pull all wires through the holes in the base.
D. Secure the base to the wall using wall anchors and screws (supplied). Make the appropriate connections.
E. Mount the control module on the base and secure using the screw.



BACnet or Modbus Address DIP Switch (DS2)

MAC address for communication, are selectable by DIP switch using binary logic. If you do not change device instance in program mode, it will be automatically modified according to the MAC address.

Note: Avoid using addresses above 246 when selecting Modbus MAC address.


MAC Address	DS.1 = 1	DS.2 = 2	DS.3 = 4	DS.4 = 8	DS.5 = 16	DS.6 = 32	DS.7 = 64	DS.8 = 128	Default Device Instance
0	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	153000
1	ON	OFF	OFF	OFF	OFF	OFF	OFF	OFF	153001
2	OFF	ON	OFF	OFF	OFF	OFF	OFF	OFF	153002
3	ON	ON	OFF	OFF	OFF	OFF	OFF	OFF	153003
4	OFF	OFF	ON	OFF	OFF	OFF	OFF	OFF	153004
…	…	…	…	…	…	…	…	…	…
126	OFF	ON	ON	ON	ON	ON	ON	OFF	153126
127	ON	ON	ON	ON	ON	ON	ON	OFF	153127

** Slave addresses available by setting DS.8 to ON*

Wiring

We strongly recommend that all Neptronic products be wired to a separate grounded transformer and that transformer shall service only Neptronic products. This precaution will prevent interference with, and/or possible damage to incompatible equipment.


For 120/240Vac models, it is recommended to have separate power sources for the EFCB controller and the Fan Coil Unit, in order to protect the device circuitry from any surge in power supply.



PCB Drawings

TFL54 Digital Room Sensor

3 wire cable (TB1 #1, 2 & 3)
Connect TB1 #6 (A+) & #7 (B-) to EFCB to enable the BACnet service port.




Mode Selection (JP1)

JP1 RUN PGM	**RUN:** Digital Room Sensor is in **Operation Mode**. Digital Room Sensor must be set in this mode to operate properly. If not locked, setpoint, fan speed and control mode (Heating & Cooling ON, Cooling only ON or Heating only ON) can be modified by end user.
JP1 RUN PGM	**Jumper (JP1) on PGM:** Digital Room Sensor is set in **Programming Mode**. Refer to following section about all settings description

TDF10 / TDF40 / TDF70 Series

3 wire cable (TB1 #1, 2 & 3)
Connect TB1 #6 (A+) & #7 (B-) to EFCB to enable the BACnet service port.




Mode Selection (JP1)

JP1 RUN PGM	**RUN:** Digital Room Sensor is in **Operation Mode**. Digital Room Sensor must be set in this mode for normal system operation. If not locked, setpoint and control mode can be changed by the end user.
JP1 RUN PGM	**PGM:** Digital Room Sensor is set in **Programming Mode**. Refer to the following sections for more details.

TDF00 / TDF30 / TDF60 Series

3 wire cable (TB1 #1, 2 & 3)
Connect TB1 #6 (A+) & #7 (B-) to EFCB to enable the BACnet service port



Mode Selection (JP1)

JP1 R P	**RUN:** Digital Room Sensor is in **Operation Mode**. Digital Room Sensor must be set in this mode for normal system operation. If not locked, setpoint and control mode can be changed by the end user.
JP1 R P	**PGM:** Digital Room Sensor is set in **Programming Mode**. Refer to the following sections for more details.

Access to Menus

The menu overviews and options are the same for both TFL54 and TDF digital room sensors. However, the action button or the button used to access the menus and save changes is different in the digital room sensors. Use the following menu overviews with the appropriate action button as per your digital room sensor.

Action Buttons on Digital Room Sensor

Action Button			Task
TFL54	TDF	TDU*	
			Press to access the programming menus and save any changes.
			Press to return to the previous step without saving.


**** If the EFCB controller is being configured using a TDU digital room sensor, use the corresponding buttons shown in the table above to navigate through the menu.***

Note: Prior to going into Programming Mode, remove the connection cable between the EFCB and the TFL/TDF/TDU and set the Mode Selection jumper (JP1) to PGM on the digital room sensor. Reestablish the connection in order to access the programming menus and to make any changes. Once all menu changes have been made, remove the connection cable again before setting jumper JP1 back to RUN, and then reconnect the cable to resume normal operation.

Analog Inputs – Menu Overview (1 of 8) | *AI2 to AI6*

Main Menu | **Sub Menu** | **Configuration**


*** To save any changes, press on TFL and on TDF ***
*** To return to the previous step without saving, press on TFL and on TDF ***




Digital Inputs – Menu Overview (2 of 8) | *DI1 to DI4*

Main Menu | **Sub Menu** | **Configuration**


**** To save any changes, press on TFL and on TDF ****
**** To return to the previous step without saving, press on TFL and on TDF ****



TRIAC Outputs – Menu Overview (3 of 8) | *TO1 to TO4*




Analog Outputs – Menu Overview (4 of 8) | *AO1 to AO4*




Digital Outputs – Menu Overview (5 of 8) | *DO1 to DO4*

Main Menu | **Sub Menu** | **Configuration**

**** To save any changes, press on TFL and on TDF ****
**** To return to the previous step without saving, press on TFL and on TDF ****



Settings – Menu Overview (6 of 8) | *Temp, Fan, Settings and Ramps*



Network and Calendar – Menu Overview (7 of 8) | *Network, Time and Buttons*

Main Menu	Sub Menu	Configuration

*** To save any changes, press on TFL and on TDF ***
*** To return to the previous step without saving, press on TFL and on TDF ***

▲▼= scroll menu items

- Main Menu
- InP M *(Inputs)*
- Out M *(Outputs)*
- tNP M *(Temperature)*
- FAN M
- SEt M *(Settings)*
- rP M *(Ramps)*
- **NEt M** *(Network)*
- **HrS M** *(Hours – Time & Date)*
- **BtN M** *(Buttons)*
- Hu M *(Humidity)* *Only available with* ***TFLH54***

▲▼= scroll menu items

NETWORK CONFIG
- **tYP NEt** *(Type)*
- **Md**
- **bAc**
- **CPy** *(copy configuration)*

If type = bAC, menu contains "tYpe", "bAC" and "CPY"

If type = mOd, menu contains "tYpe and "mOd"

▲▼= select / set value

NETWORK CHOICE
- **bAC** *(BACnet)* — Go to "bAC"
- mOd *(Modbus)* — Go to "mOd"

▲▼= select / set value

ABR (Modbus Auto Baud Rate)
- NO *(Manual)*
- **YEs** *(Automatic)*

→ BAU (Modbus Baud Rate)
57.6k *(9.6k, 19.2k, 38.4, 57.6k)*
Modifiable only if Auto Baud Rate set to "No".

→ CF9 (Modbus Comport Config)
- **NP2** *(no parity, 2 stop bits)*
- EP1 *(even parity, 1 stop bit)*
- OP1 *(odd parity, 1 stop bit)*

→ MA (Modbus Address)
1 *(1-246)*
Modifiable only if all DS2 DIP switches are set to OFF.
→ Go to "HrS"

▲▼= select / set value

ABR (BACnet Auto Baud Rate)
- NO *(Manual)*
- **YEs** *(Automatic)*

→ BAU (BACnet Baud Rate) *1001*
76.8k *(9.6k, 19.2k, 38.4, 76.8k)*
Modifiable only if Auto Baud Rate set to "No".

→ ADD (MSTP MAC Address) *1000*
0 *(0-254)*
Modifiable only if all DS2 DIP switches are set to OFF.

→ MSTP MAX MASTER
127 *(1-127)*
→ Go to "CPy"

▲▼= select / set value

ADD (Start Address) *AV.165*
0 *(0-254)*

→ ADD (End Address) *AV.166*
0 *(0-254, start address+63)*

→ CPY (Confirm Copy Config) *BV.90*
- **NO** *(cancel)*
- YEs *(confirm)*

→ Go to "HrS"

COPY CONFIGURATION
in *(in progress)*

→ COPY CONFIG SUCCEEDED
SCd *(done)* *AV.167*
→ Go to "HrS"

▲▼= select / set value

SET TIME DISPLAY FORMAT
- **24** *(24-hour format)*
- 12 *(AM/PM format)*

→ HOURS *Local Time*
12 *(0-23 or 1-12 am/pm)*

→ MINUTES *Local Time*
00 *(00-59)*

→ YEAR *Local Date*
15 *(15-99)*

→ MONTH *Local Date*
1 *(1-12)*

→ DAY *Local Date*
1 *(1-31)*
→ Go to "BtN"

▲▼= select / set value

BLK (Bottom Left Key Locked)
- **NO**
- YES

→ ULK (Upper Left Key Locked)
- **NO**
- YES

→ AK (Arrows Key Locked)
- **NO**
- YES


→ Go to "Hu"

Humidity – Menu Overview (8 of 8) | *Humidity*

Only available when a humidity sensor digital room sensor is connected to the controller.

Main Menu	Sub Menu	Configuration

*** To save any changes, press on TFL and on TDF ***
*** To return to the previous step without saving, press on TFL and on TDF ***
*** The Hu (Humidity) menu is available only on digital room sensor with humidity ***




Operation Menus

This menu is accessible through normal operation mode.
Note: Since the action buttons are different on the TFL24 and TDF digital room sensor series, both buttons have been included in the instructions. Refer to the Action Buttons on section to know and use the button as available on your digital room sensor.


1. The Mode Selector jumper (JP1) of the digital room sensor must be set to the "RUN" position (Operation Mode). Refer to Wiring on page 9.
2. Press the [⏻ / 🌀] and [❄/🔥 / ❄🔥] buttons simultaneously for 5 seconds. The "Enter Password" screen appears.
3. Enter the password within 1 minute by using the arrow keys to increase or decrease the value and the [⏻ / 🌀] and [❄/🔥 / ❄🔥] buttons to toggle between the digits.
   a. Password **372** = Sensor Offset Menu
   b. Password **637** = Network Settings Menu
4. If you enter the wrong password, the digital room sensor displays "**Eror**" and returns to Operation Mode. The digital room sensor will return to normal mode if you navigate through the entire menu and do not make any selection, or if you do not press any key for 5 minutes. The changed values will be saved automatically.

Menu 372 – Sensor Offset



****** To save any changes, press ⏻ on TFL and 🌀 on TDF ******
****** To return to the previous step without saving, press ❄/🔥 on TFL and ❄🔥 on TDF ******

Menu 637 – Network Settings



****** To save any changes, press ⏻ on TFL and 🌀 on TDF ******
****** To return to the previous step without saving, press ❄/🔥 on TFL and ❄🔥 on TDF ******

Reset to Factory Default Settings


⚠	**This will erase all actual configurations and replace them with the factory default settings.**

1. The Mode Selector jumper (JP1) of the digital room sensor must be set to the "RUN" position (Operation Mode). Refer to Wiring on page 9.
2. During the power up sequence of the controller and digital room sensor, press and hold both the [❄/🔥 / ❄🔥] and ▼ buttons.
3. The "Enter Password" screen appears. Enter **372** within 1 minute by using the arrow keys to increase or decrease the value and the [⏻ / 🌀] and [❄/🔥 / ❄🔥] buttons to toggle between the digits.
4. Use the arrow buttons to select YES and then press [⏻ / 🌀].


Operation Mode

The Mode Selector Jumper of the digital room sensor must be set to the “RUN” position (Operation Mode). Refer to Wiring on page 9.


TFL54



TDF10 / TDF40 / TDF70 Series



TDF00 / TDF30 / TDF60 Series



Power Up

Upon power up, the LCD illuminates and all segments appear for 2 seconds. The digital room sensor then displays its current version of the digital room sensor for 2 seconds followed by the current version of the controller for 2 seconds. Pressing any key on the digital room sensor illuminates the LCD for 4 seconds.

Temperature Display and Setpoint

The digital room sensor displays the temperature reading. If the sensor is disconnected or short circuited, the unit displays the sensor's limits. To toggle the temperature scale between ºC and ºF, press both the ▲ and ▼ keys for 3 seconds. To display the setpoint, press the ▲ and ▼ key twice. The set point appears for 5 seconds. To adjust the setpoint, press the arrow keys while the temperature is displayed. If the setpoint adjustment has been locked, the lock 🔒 symbol appears.

Temperature and Humidity (Digital Room Sensors with Temperature and Humidity)

The digital room sensor displays the temperature reading for 8 seconds and then displays the humidity reading for 2 seconds. If the sensor is disconnected or short circuited, the unit displays the sensor's limits. To toggle the temperature scale between ºC and ºF, press both the ▲ and ▼ keys for 3 seconds.

To access the Humidity setpoint, press the [/] button for 5 seconds. The humidity setpoint will be displayed for 5 seconds. To adjust the setpoint, press the ▲ and ▼ keys while the setpoint is displayed. The unit will return to normal mode if you do not press any key for 3 seconds. The changed values will be saved automatically.

Control Mode

To access the Control Mode, press the [/] key. The Control Mode appears for 5 seconds. Press the [/] key to scroll through the following control modes. These options can vary depending on the options selected.

- Auto (Automatic Cooling or Heating)
- Cooling only (on, with cooling symbol)
- Heating only (on, with heating symbol)
- OFF (if it is not disabled in Programming Mode)

Fan Speed Selection Mode

To access the Fan Speed selection mode, press the [/] key. The mode appears for 5 seconds. These options can vary depending on the fan speed signal and auto mode settings. If in No Occupancy mode, the [/] button now serves as the override button.

- Automatic speed. Available only if enabled in Programming Mode.
- Low speed
- Medium speed
- High speed
- Off. Off is not selectable by the user, it appears only if the "Control Mode" is "Off" and it indicates that the user can not change the speed of the fan.

Night Setback (NSB)

This function is only available if you've set DI3 to **nSb** (Night setback contact) If the DI3 contact is triggered, the digital room sensor enters NSB Mode (the ☽ symbol appears) and uses the NSB setpoints defined in program mode. Press any key to override NSB for the delay defined in program mode (default: 120 minutes). The ☽ symbol flashes to indicate that the NSB mode is overridden (during this time the standard set points are used).


If the NSB Mode was set to OFF, all outputs will be off for the duration of the period and cannot be overridden.

Occupancy Mode

This function is only available if you've set DI3 to **Occ** (occupancy mode). If the DI3 contact is triggered, the digital room sensor enters Occupancy Mode (the ☽ symbol appears) and uses the NoOcc setpoints defined in Programming Mode.
If not locked, no occupancy mode can be overridden for a period by pressing the [/] button. Each time you press the [/] button, 15 minutes are added to the override (up to a maximum defined in program mode).
Press the fan [/] button until "0" is displayed to disable the override. The ☽ icon will flash and the remaining override time will be displayed in minutes.

Set Time and Date

1. Ensure that JP1 on the digital room sensor is set to run.
2. Press and hold the [❄/🔥 / ❄🔥] button for 5 seconds.
3. Use the arrow keys to set the desired value. Press the [🌀 / 🌀] button to save and go to the next step. Press the [❄/🔥 / ❄🔥] button to go to the previous step without saving.



****** To save any changes, press 🌀 on TFL and 🌀 on TDF ******
****** To return to the previous step without saving, press ❄/🔥 on TFL and ❄🔥 on TDF ******

*Note: The time and date will only be displayed after activating the BACnet schedule through the binary object **BV.70** set to **1**.*

	Recycling at end of life: please return this product to your Neptronic local distributor for recycling. If you need to find the nearest Neptronic authorized distributor, please consult **www.neptronic.com**.



400 Lebeau blvd, Montreal, Qc, H4N 1R6, Canada
www.neptronic.com
Toll free in North America: 1-800-361-2308
Tel.: (514) 333-1433
Fax: (514) 333-3163
Customer service fax: (514) 333-1091
Monday to Friday: 8:00am to 5:00pm (Eastern time)